

**REVISED DETAILED  
PROCEDURE  
FOR  
GRANT OF  
GRID CONNECTIVITY TO  
THE INTRA STATE  
DISTRIBUTION SYSTEM**

**REVISED DETAILED PROCEDURE FOR GRANT OF GRID  
CONNECTIVITY TO THE INTRA STATE DISTRIBUTION SYSTEM**

**1.0 OUTLINE**

1.1 This Procedure is evolved in accordance to regulation 43 of the Tamil Nadu Electricity Regulatory Commission Grid Connectivity and Intra State Open Access Regulations,2014 (herein after referred to as Regulations) and its various other provisions. All applicants shall abide by the provisions of the Regulations, as amended from time to time, and the procedures laid down hereunder.

1.2 This Procedure shall apply to the Applications made for Grant of Grid Connectivity to the Intra-state Distribution system at 33 kV level and below on or after the date notified by the Commission by which the Regulations will come in to force..The procedure shall be read with provisions of these regulations, Electricity Act, 2003 and prevailing TNERC Regulations/orders.

**1.3 Connectivity:**

1.3.1 Any consumer having contracted demand of less than 10 MW or a consumer availing supply at 33 kV and below or a Generating station having installed capacity less than 15 MW or a Generating station requiring connectivity at 33 KV and below shall be eligible to obtain connectivity to the Intra-state Distribution system and shall apply for connectivity as per this procedure, unless already connected.

1.3.2 The nodal agency for grant of connectivity, long term, medium term and short term open access shall be the agency notified in the Regulations.

1.3.3 Open Access customers already connected to the grid shall not be allowed to apply for additional connectivity within the same approved capacity. In case of enhancement of capacity, they shall be required to make application of connectivity

as per the provisions of the Regulations. In case of reduction in capacity, approval shall be obtained from the nodal agency as notified in Regulations.

1.3.4 Applications for grant of connectivity shall normally be submitted to the Chief Engineer/Grid Operation, SLDC Block,144, Anna Salai, Chennai – 600 002. At present the State Load Dispatch Centre (SLDC) is not equipped to handle applications from all categories of generators. Till such time the SLDC is equipped to handle all applications, applications shall be submitted to the officers as below or as may be notified by the Distribution licensee:

Sl.No.	Description	Authority
1.	For grid connectivity at 33 kV and below:	
	(a) Fossil fuel based generating plants/Co-gen plants/Consumer (Non-RE)	Chief Engineer/PPP, VI Floor, Eastern wing, NPKRR Maaligai, 144,Anna Salai, Chennai – 600 002.
	(b) Renewable Energy generators	Chief Engineer/Non Conventional Energy Sources, II Floor, Eastern wing, NPKRR Maaligai, 144,Anna Salai, Chennai – 600 002.

1.3.5 Applicant granted 'connectivity' will be required to sign connection agreement ie Grid connectivity agreement with the territorial SE/EDC to be indicating by the Authority tabled above prior to the physical inter-connection. In case the connectivity is granted to the intra-State distribution system of an intra-State distribution licensee other than TANGEDCO, a tripartite agreement shall be signed between the applicant, TANGEDCO and such intra State distribution licensee, in line

with the provisions of the regulations. The nodal agency shall always have a copy of the agreement.

**2.0 Procedure to submit application form, documents and Payment of fee:**

2.1 The application for grant of connectivity shall be made in the prescribed format **(FORMAT – 1)** along with documents mentioned in the format of application. The application shall contain details such as geographical location of the generation project, quantum of power to be interchanged, that is, the quantum of power to be injected in the case of a generating station including a captive generating plant and quantum of power to be drawn in the case of a consumer, unit wise commissioning schedule etc.

2.2 Connectivity shall be granted at appropriate system voltages based on technical guidelines on loading of lines for generators and as stipulated in Regulations/Codes for consumers. The generators shall be connected to the substation by a separate feeder and no distribution loads will be permitted to be connected in such feeders.

2.3 In order to assess preparedness of the applicant for receiving connectivity, an applicant is required to submit along with the application, documents, as detailed below and as applicable, in support of having initiated specific action with respect to project preparatory activities:

1.	Site identification and land acquisition	Land required; present stage of acquisition; expected date of completion of acquisition.
2.	Environment clearance	The details of submission of application to the concerned authority and its status(first level submission)
3.	Forest clearance (if applicable)	The details of submission of application to the concerned authority (First level submission).
4.	Fuel arrangement	Quantity of fuel required for the installed capacity; source of fuel; agreement executed for

		fuel supply; <i>stock of fuel.</i>
5.	Water linkage	Quantity of water requirement; application made; status of approval by appropriate authority.

2.4 The applicant shall indicate the location of consumers where power is proposed to be transmitted / wheeled. If it is not possible to indicate the location of consumers, the Circle/Region to which power is to be transmitted /wheeled has to be indicated. In case applicant is a consumer, the applicant shall indicate the location of generator from where the power is proposed to be received. This is required to ascertain the power flow while examining grid connectivity.

**2.5 Application fee for Connectivity:**

2.5.1 The application for connectivity shall be accompanied by a non-refundable fee of Rs.1 Lakh in case of conventional fuel based generators & in case of co-generation and generation of electricity from renewable Energy sources, the application fee shall be 50% of the normal fee.

2.5.2 The application fee (excluding service tax/GST) is inclusive of charges for any load flow or system studies to be conducted by Distribution Licensee.

2.5.3 The application fee shall be paid through DD drawn in favour of Chief Financial Controller/General/TANGEDCO/ Chennai – 2 payable at Chennai/online payment mode in the TANGEDCO account.

2.5.4. The date of receipt of application in complete shape by the Distribution licensee will be reckoned as the date of registration and an acknowledgement furnished for the same to the applicant.

2.5.5. Applications incomplete or not in conformity with the procedure/regulations shall be rejected and the same informed to the applicant and application fee already paid will be forfeited.

2.5.6. In cases where once an application has been filed and thereafter there is any material change in the location of the applicant or change by more than 10 per cent in the quantum of power to be inter changed with the Distribution system, the applicant shall make a fresh application along with applicable fees and the already filed application shall be considered disposed and application fee forfeited.

2.5.7 An application by collective generators shall be considered by the Distribution licensee only if all the generators, whose aggregate capacity is connected at the single connection point, formalize a written agreement among themselves that the lead generator shall act on behalf of all generators to undertake all operational and commercial responsibilities for all collective generators as provided in the Regulations.

2.5.8 If any applicant has already been granted connectivity but the process of construction by the Distribution licensee or by the generating company has not yet started and the applicant subsequently applies afresh with material changes or change by more than 10% in the quantum of power to be interchanged, then the already granted connectivity shall stand cancelled.

2.5.9 The load flow studies are carried out corresponding to the commissioning schedule proposed by the generator at the time of Grid connectivity application. Hence, the generator shall adhere to the commissioning schedule proposed at the time of application.

2.5.10 Application for any minor changes i.e material change in location or change within 10% of installed capacity shall have to be re-submitted in the same application format marked as 'revised'.

### **3.0 Grant of connectivity**

3.1 On registering the application received in complete shape, the distribution licensee shall carry out interconnection study as provided in the Regulation 8 of Grid Connectivity and Intra State Open Access Regulations 2014 to ascertain the feasibility of connecting the generator with its network and convey its decision on grant of connectivity or otherwise within 30 days from the date of receipt of application in complete shape, furnishing details as in sub clause 3.3 of this clause.

3.2 Every applicant shall construct a dedicated line to the point of connection to enable connectivity to the Distribution licensee's system in accordance to Regulation 8(8) of the Commission's Grid connectivity and Intra State Open Access regulations, 2014.

3.3 While conveying the decision for grant of connectivity as in Para 3.1 to the applicant, the following will be informed:

- i. Based on the results of the study, the applicant will be informed of the proposed interconnection line / dedicated Distribution line for connectivity with broad design features, the substation / pooling station/ switchyard/ point of connection to which the line is to be connected.
- ii. The applicant shall arrange to provide pooling station/switchyard facilities (that includes transformers, structures, breakers, CTs, protection arrangements, data communication system which includes online data transfer to SCADA server and AMR data transfer etc.) at their end.

- iii. The details of augmentation to be carried out to accord connectivity will be specified. In case of augmentation, the applicant shall bear the cost of bay extension and initial testing and commissioning.
- iv. In the case of Distribution Licensee carrying out the works of constructing dedicated line, the estimated amount shall be deposited to the Distribution Licensee.
- v. The timeframe for completion of the dedicated line shall be informed by the Distribution Licensee or the applicant as the case may be.

3.4 The applicant shall convey concurrence or otherwise of the proposal of Distribution licensee to grant connectivity **within 30 days** of receipt of proposal informing the time period for construction of dedicated line failing which the Distribution licensee may cancel the application. Thereafter, a fresh application with necessary fee shall be furnished by the generator.

3.5 On receipt of concurrence from the generating company, approval for grid connectivity to the Intra State Distribution system will be accorded within 15 days.

3.6 The applicant shall sign a Grid connectivity Agreement (**FORMAT - 2**) with the distribution licensee (territorial SE/EDC to be indicating by the concerned nodal agency) prior to the physical inter connection where connectivity is being granted, **within 15 days** of issue of approval for connectivity, failing which Distribution Licensee reserves the right to cancel the application without any further notice.

3.7 The consumers who wish to avail open access as per the provision of ISOA Regulations 9(3) & 9(6) are required to seek grid connectivity through independent feeder.



Provided that the consumers who are not on independent feeders, shall be allowed open access subject to the load restrictions in the feeders serving them in line with the Commission's Regulations / Codes / Orders.

3.8 The entire cost of extension from sub-station to the consumer including the bay provision at SS end, take off arrangement, applicable O&M charges etc., is to be borne by the consumer subject to the availability of bay and way leave provisions.

3.9 In the event, the consumer do not avail open access for a period exceeding 6 months, the independent feeder status will be withdrawn and they will be treated on par with other consumers.

#### **4.0 Connectivity agreement with existing generators:**

4.1 The existing generators connected at various voltage levels shall continue the same as per the provisions of the executed agreements. However, the provisions of this Regulations and procedure for connectivity shall also be applicable. In case of enhancement of capacity or additional capacity etc., they shall be required to make fresh application of connectivity as per the provisions of the Regulations by which the generators shall be connected to the substation through a separate feeder and no distribution loads will be permitted to be connected in such feeders.

#### **5.0 Estimation of cost, construction of dedicated distribution line, payment of charges.**

5.1 The Distribution Licensee will be furnishing estimate for cost of bay /switching station, as the case may be, including switchgear and protection arrangement and supervision charges after the execution of Grid Connectivity Agreement. The generator/ consumer shall pay the cost within 30 days of receipt of estimate failing which the Distribution Licensee reserves the right to cancel the application without

any further notice. Thereafter, fresh application with application fee is to be furnished by the applicant if connectivity is required.

5.2 Distribution Licensee shall carry out bay works, augmentation etc after payment by the generating company/ consumer.

5.3 The applicant has to erect the dedicated Distribution line by themselves as per the provisions of section 9, 10(1) of the E-Act, 2003, as per the design features communicated and under the supervision of Distribution Licensee's officials. The cost of augmentation of licensee's substation includes cost of bay provision / provision of switching stations including that of land required, as the case may be, switchgear, other equipments, protection arrangements, data communication system including online data transfer to SCADA server and AMR data transfer, testing and commissioning etc, which shall be borne by the applicant. The ownership of the interface line (dedicated line from their plant to the point of connection) if erected by the generating company under section 9, 10(1) of the E-Act, 2003 will rest with the generating company and the company shall operate & maintain the line by themselves subject to getting clearance from the appropriate agency/officials before taking up any preventive/break down maintenance works. The entire responsibility of safety of company's personnel rest with the company and the licensee will not be responsible for any untoward incidents and not liable to pay any compensation in this regard. However, the maintenance of bay equipments at the substation/ switching stations as the case may be where the interfacing line gets terminated will be operated and maintained only by the licensee subject to the condition that the cost of maintenance and spares as may be notified by the licensee from time to time shall be borne by the company.

5.4 The bills shall be raised by the licensee towards bay / switching station maintenance as the case may be on annual basis and the generator shall pay the amount within 5 working days of receipt of bill.

5.5 In case of delay in execution of works either by the generating company or Distribution Licensee, in both the cases the parties can mutually agree for revised schedule of completion of works.

### **6.0 Interchange of power with the grid**

6.1 The grant of connectivity shall not entitle an applicant to interchange any power with the grid unless the applicant obtains long term open access, medium term open access or short term open access as the case maybe in accordance with the provisions of the Commissions Open Access regulations in force and subsequent amendments.

6.2 Any interchange of power with grid without any type of valid open access shall not warrant any payment to be made by any licensee. Besides, such quantum of power will not be adjusted against any consumption. Such inter change of power shall be in violation to the Grid connectivity and Intra State Open Access Regulations,2014 and shall be dealt with in accordance with the provisions of the Electricity Act,2003. The provisions of this sub-clause shall not be applicable to the energy exchange specified sub clause 3 of this clause.

6.3 Before availing any open access, the generator including captive generating plant / co-gen plant/Non conventional plant which has been granted connectivity to the grid shall be allowed to pump infirm power into the grid during testing including full load testing before its COD for a period not exceeding **six months** from the date of first synchronization after obtaining prior permission of the concerned SLDC/

Distribution Licensee. For any extension of period for testing, full load testing and consequent injection of infirm power by the unit beyond six months the generator shall approach the Commission at least two months in advance of the completion of the six month period.

6.4 The onus of proving that the injection of infirm power from the units of the generating station is for the purpose of testing and commissioning shall lie with the generating company and the SLDC shall seek such information on each occasion of injection of power before COD. For this, the generator shall provide SLDC sufficient details of the specific testing and commissioning activity, its duration and intended injection etc. Such details shall be shared with the distribution licensee also. The company has to get specific approval of TANGEDCO/Nodal agency for injecting infirm power, who has to pay for the infirm power, before effecting connectivity. Commercial treatment including the tariff for such infirm power from a generating station or a unit thereof will be governed by the concerned Regulations/Orders in force issued by the Commission from time to time.

6.5 On completion of all erection works (generator/lines, etc) by the generating company as well as by the Distribution licensee, provision of ABT meter with DLMS facility and establishment of online data connectivity with AMR server at SLDC, the company shall inform Distribution licensee/Nodal agency for concurrence of synchronization of generator with the distribution system and Distribution licensee shall issue concurrence for the same, taking into account the field condition.

6.6 Synchronizations of the generating unit with the distribution system shall be permitted only after ensuring proper protection arrangement by officials of Distribution licensee/SLDC and after obtaining statutory clearances like consent to

operate from MOEF, TNPCB, clearance from various authorities such as CEIG etc. The synchronization (for the first time) shall be in presence of the officials of Distribution licensee and shall be with consent of SLDC.

6.7 It is the sole responsibility of the generator to declare COD of the generator. The date of declaration of COD and the capacity of the individual unit shall be final. In case of combined cycle plant, the date of COD will be reckoned with the declaration of commercial operation of combined cycle. Further, the capacity declared on COD shall not exceed the manufacturers rated capacity (Maximum Continuous Rating as per design). There can be only one COD.

6.8 At the time of synchronization as well as at the time of COD, meter readings at Interface point shall be taken.

6.9 The generator shall be synchronized in presence of TANGEDCO's officials. Payment for the energy pumped if any for testing and commissioning purpose from the date of synchronization till declaration of COD will be paid as per the formula notified in TNERC's Amendment to the terms and condition for determination of Tariff Regulations 2005, dt.09.04.2014. On attaining COD the company shall furnish the details of energy pumped till COD to this office for fixing of tariff as per the formula notified by TNERC. Necessary clearance shall be obtained from JLDC/SLDC before pumping energy for testing and commissioning.

6.10 The company shall inform the date of synchronization and COD to Nodal agency concerned and the SE/EDC concerned and the bills for such supplies shall be submitted to the SE/EDC concerned for payment.

## **7.0 Provision of interface meters**

7.1 ABT meters with DLMS facility: ABT compliant interface meters with DLMS facility shall be installed as specified in the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006 as amended from time to time, and in accordance to the Commissions Grid connectivity and intra State Open Access Regulations, 2014. The meters shall have facility for communication of data on real time basis to SCADA server and AMR data transfer suitable to the protocol specified by STU / licensee. Energy accounting and settlement shall be done in 15 minutes block. From the energy / demand recorded in the Consumer meter, scheduled OA entitlement shall first be adjusted to arrive at energy / demand consumption from TANGEDCO.

7.2 The check meters (ABT meter) shall be provided by the STU or if the licensee, requests the generator to provide the same, the cost of the meter will be reimbursed / adjusted with the bills on submission of proper invoice.

7.3 In case of captive loads within the generator premises, the industrial loads shall be segregated in such a manner that the ABT meter provided for recording startup power records exclusively auxiliary consumption used for startup power. This energy will be deducted from the energy recorded in the main meter (interface) provided at the switchyard where incoming supply is received. Similarly the demand recorded in the above ABT meter (during the period of startup) provided for measuring auxiliary load consumption will be deducted from the demand recorded in the main ABT meter. Excess demand charges as per the relevant regulations/orders shall be applicable whenever the sanctioned demand is exceeded.

7.4 Generators shall install energy accounting meter(s) which are ABT compliance with DLMS facility and communication facilities (Modem or DCU) in order to record generation in each units and auxiliary consumption, as per CEA Regulations 2006 and subsequent amendments thereof. Generator shall establish day survey, load survey and instantaneous data transfer facility to the servers at SLDC.

7.5 At the time of submitting application for grid connectivity the applicant shall incorporate the location of all ABT meter(s) (interface & Energy accounting) proposed to be provided as mentioned above in the single line diagram.

7.6 After approval of location of meters, the generating company shall not shift the meters without specific approval of Transmission/distribution licensee

## **8.0 Startup power**

8.1 The generators shall approach the Distribution licensee (the concerned Superintending Engineer of the Electricity Distribution Circle in whose jurisdiction the generating plant exists) for obtaining start up power from the grid. The generating company at the time of submitting the application for grid connectivity shall indicate the requirement of startup power if required and the demand required for such start up power.

8.2 The startup power will be permitted only within the percentage approved by the Commission. This power is to be used only for startup operation after declaration of COD. The period of startup power will be as specified in the Regulations.

8.3 However, during construction period the generators shall avail power for construction purpose on temporary basis by filing a separate application to the distribution licensee. Supply obtained for the construction period shall be paid at appropriate tariffs as fixed by the Commission in its tariff order from time to time.

8.4 In case of industrial service connections where the captive Generating Plant is also connected, in order to ascertain startup power consumption, ABT compliance meter (as per CEA Regulation 2006) shall be provided at the incoming breaker ie at the primary side of the transformer which feeds exclusively to the auxiliary loads of the generator(s) fed from TANGEDCO supply. The industrial loads should be segregated in such a manner that the ABT meter provided for recording startup power records exclusively auxiliary consumption used for startup power only. The recorded energy in the above meter will be billed at the rate notified by TNERC for startup power. This energy will be deducted from the energy recorded in the main meter (interface) provided at the switchyard where incoming supply is received. Similarly the demand recorded in the above ABT meter (during the period of startup) provided for measuring auxiliary load consumption will be deducted from the demand recorded in the main ABT meter and the balance will be billed under industrial tariff and also accounted for R&C measures whenever in force. The demand recorded for startup power will be billed as per the tariff notified by TNERC. In case if the demand recorded for startup power exceeds the demand permitted for startup power, penalty will be levied as per Tariff order.

8.5 Further if the startup power demand recorded is within the sanctioned limits but the industrial demand shoots up (after deducting startup demand), then penalty will be levied for the excess demand as per Tariff order in force. The period of startup power will be as per ISOAR 2014.

8.6 Further ABT meters of 0.2 S class accuracy shall be provided at all the outgoing feeder of the captive generating plant feeding various loads, where CGP & industrial loads are available within the same premises, for energy accounting.



## **9.0 Application for Mere Parallel operation**

9.1 Application in the prescribed format (**FORMAT-1**) shall be submitted along with necessary documents and with non-refundable fee specified in para 2.5 of this procedure.

9.2 In case parallel operation is not feasible with the existing line & substation and if any augmentation is required, the same will be communicated to the generator. The generators seeking parallel operation shall construct a dedicated line to the point of connection to enable connectivity to the distribution system.

9.3 In case of feasible parallel operation with the existing dedicated distribution line & substation, the generator shall bear/pay the cost of the existing dedicated distribution line to Distribution Licensee/TANGEDCO.

9.4 The procedure for parallel operation of the generators with Grid shall be the same as the procedure mentioned for grid connectivity of generators with evacuation into grid.

9.5 On receipt of approval the applicant shall execute agreement for grid connectivity (**FORMAT-2**) with Distribution Licensee concerned within **15 days** of receipt of approval.

## **10.0 Parallel Operation Charges**

10.1 Parallel operation charges are to be paid for net captive capacity (ie installed capacity less open access capacity) as notified by the Commission in the Grid connectivity and Intra-state Open access Regulations, 2014 and subsequent amendments /Orders.

10.2 The charges towards parallel operation will be claimed by the SE/EDC

concerned within 3<sup>rd</sup> working day of the succeeding month and the generator shall pay the amount within 5 working days of receipt of bill.

## **11.0 Captive Generating Plants / Co- generating Plants**

### **11.1 Captive Generating Plant Status verification**

In case of captive generating plants, they shall maintain CGP status as per Rule 3 of Electricity Rules and shall furnish the prescribed documents and formats as per TNERC's order in R.A.No.7 of 2019, dt.28.01.2020 for verification of CGP status as and when required by the distribution licensee.

### **12.0 CO-Generating Plant Status verification**

12.1 The Co-gen holder shall furnish necessary documents and maintain Co-gen status as per MOP resolution A-40/95- IPC-1, dt.06.11.1996 and TNERC's order No.4, dt.15.05.2006 before 31<sup>st</sup> January of succeeding Calendar year to the SE/EDC concerned.

## **13.0 General**

13.1 Where a dedicated Distribution system used for open access has been constructed for exclusive use of an open access customer by the Distribution licensee, the additional wheeling charges for such dedicated system shall be worked out by the licensee and got approved by the Commission and shall be borne entirely by such open access customer till such time the surplus capacity is allotted and used by other persons or for other purposes.

13.2 In case, the intra state distribution system or transmission system is used by an open access customer in addition to inter-state transmission system, transmission charges and wheeling charges as fixed and approved by the Commission shall be

payable for use of intra-state system in addition to payment of transmission charges for inter-state transmission.

13.3 The applicant shall abide by the provisions of the Electricity Act, 2003, Rules framed there under, Commission's Regulations/Orders as amended from time to time. The Captive Generating Plants, Co Generating Plants shall abide the relevant rules, orders, instructions of Ministry of power in all aspects such as CGP/co-gen status, holding of equity, proportion of energy consumption etc.

13.4 This is displayed in website for comments from stake holders. After receiving the same and suitably modifying the above procedure if required the same will be placed before the Commission for approval.

Similarly if any teething problem is experienced or implementing the same will be reviewed or revised by the Nodal agency with prior approval of Commission.

## **FORMAT -1**

### **Application for Grid Connectivity of Fossil fuel based Generators/Captive Generating Plants/Waste heat recovery based Co-gen plants/Renewable Energy generator at voltage 33 KV and below**

Sl.No	DETAILS REQUIRED	PARTICULARS
<b>Details of the Applicant</b>		
1.	A	Full Name of the Applicant
	B	Full Address of the Applicant
	C	Name and address of the Director(s) with Contact Telephone Numbers, Cell Phone numbers, Fax Nos, E-mail ID etc. .
	D	Name and Designation of Authorized person(s) with Contact Telephone Numbers, Cell Phone numbers, Fax Nos, E-mail ID etc..
	E	Name and Designation of Contact person with Contact Telephone Numbers, Cell Phone numbers, Fax Nos, E-mail ID etc..
<b>Details of Ownership</b>		
2.	A	The power plant is <b>setup</b> by (Please clearly specify)
	B	Incorporation of the company
<b>Details of the Generating Plant</b>		
3.	A	Physical Location of the Generating Plant
	B	Details of nearby Substations
C	Type of Generating plant	Fossil fuel based generating plant/ Captive Generating Plant/ Co-Generation plant/ Waste heat recovery based Co-gen plant / Renewable Energy

			generating plant etc.
	D	Type of Primary fuel proposed In case the plant is a Fossil Fuel based one.	
	E	Whether fuel linkage has been arranged, if so furnish complete details such as source etc..	Agreements if any already executed, copy may be furnished.
	F	Whether all the statutory clearances such as TNPCB,MOE & F, Civil Aviation etc have been obtained.	Copies of clearances obtained may be furnished. Action plan for the other clearances may be furnished. Copies of such clearances may be furnished as and when the same is received.
	G	Proposed plant capacity in MW	Furnish split up details in case of more than one generator (Unit – 1,2 & 3 etc).
3.	H	If Co –generation plant/ Waste heat recovery plant etc  a) In case of Co-gen plant whether it is coming under Topping cycle/bottoming cycle b) Whether proof for qualifying as Co-gen as per MOP resolution A-40/95-IPC-1 dt.6.11.1996 is enclosed. c) Whether CGP is to run in parallel with Grid, If so the probable interfacing voltage at which paralleling to be done may be indicated. d) Whether CGP is a stand-by set and will have to run at the time of emergency only and will not feed power to the grid system of TANTRANSCO/ TANGEDCO. e) Whether CGP is to run in isolation i.e. in standalone mode and may require emergency power supply from TANGEDCO for startup	Please furnish type of industry, Process diagram and write up. Also furnish the supporting fuel proposed and details about the linkages etc.  Say Yes/No.  If no reason may be furnished

	purpose	If yes, details of requirement of backup power from TANGEDCO and voltage of supply (A separate application seeking HT supply to be submitted to Superintending Engineer of Distribution circle concerned where the generator is located.
I	Voltage level at Generator end	
J	Voltage level at Grid inter face Point	
K	Phase and Frequency in Hz.	
L	Other Technical specifications	Furnish full Technical details
M	Probable date of commissioning of different units.	
N	Whether you are already availing HT supply at the location where the Generator is proposed to be located. And the purpose for which the supply is availed may be furnished.	If yes, please furnish the HT SC No, Distribution Circle, Sanctioned Demand, Voltage level, and tariff etc..
O	Power for construction whether required	If required, quantum and level of voltage
P	Provision of ABT meter with DLMS facility	Yes/No
Q	Online data transfer communication to SLDC	Yes/No
A	i) Quantum of annual generation expected in a financial year (MU/MW) unit wise. ii) Quantum of power proposed to be used at the site itself (auxiliary consumption/Industrial consumption separately) (MU/MW) unit wise.	Aux : MU/MW (%) Indl : MU/MW
B	In case of power evacuation mentioned where the power is proposed to be taken	i) Interstate quantum in MW (location) ii) Intrastate quantum in MW ( EDC to which it is proposed ) a. Captive use b. 3 <sup>rd</sup> party sale c. Sale to TANGEDCO (The quantum at injection end will be arrived at taking into account the T&D loss as per the TNERC orders in force).

4.	C	Whether any excess energy is proposed to be sold to TANGEDCO	Say Yes or No. If Yes, a) Specify the quantum in MW to be sold to TANGEDCO. b) Whether the power proposed to be sold is Firm power and If so quantum proposed in MW/MU with relevant order from TANGEDCO c) Whether the proposed power is infirm power? If so quantum proposed in MW/MU per Annum with relevant order from TANGEDCO d) Whether the power proposed to be sold is a combination of both? If so, split up details may be furnished.
	D	Whether any Quantum to be sold to third parties	Say Yes or No If Yes quantum proposed in MW.
<b>Details for Open Access.</b>			
5.	A	LTOA /MTOA/STOA to be furnished separately The period shall be as per TNERC's Open access Regulations 2014 with quantum in MW.	
	B	If LTOA/ MTOA/STOA has already been obtained details to be furnished along with copies of the orders.	
<b>Start up power</b>			
6.	A	Whether start up power is required for the generator. If required, the quantum of demand required may be furnished. (Start up power to be availed at the same voltage level at which the interface of generator is permitted.	Application to be made to the SE/EDC concerned
<b>Interfacing line</b>			
7.	A	Whether the generator will lay the interfacing line (dedicated Distribution line) from the generator switchyard to the substation proposed to be evacuated as per the section 9, 10 (1) of the E-Act,2003.	Bay works at the SS end of TANGEDCO will be carried out by TANGEDCO/TANTRANSCO at the cost of the generating company.
	B	If so, time period required for completion of interfacing line.	
	C	If the generator proposes TANGEDCO to execute the interfacing line along with bay works at the SS under payment basis.	YES/NO
<b>For Mere Parallel Operation of Generators</b>			
	A	Total industrial load in KW	

8.	B	Sanctioned demand of service connection	
	C	Load ( KW) fed by the captive generating plant	
	D	Is the load fed by the Captive Generating plant is demarcated or the load fed by the CGP and the licensee is combined. (furnish the full details)	
	E	Protection arrangements proposed to prevent power flow to grid when the generator runs in parallel with the grid.	
	F	Power for Construction	Whether power is required for construction. If required, mentioned the quantum & voltage level ( Application to be made to the SE/EDC concerned.)
9.	A	Details of payment of application fee a. Amount b. PR.NO/Date	proof of payment to be enclosed (in original)

We hereby declare all the above details are true and correct. We are also agreeable to furnish any other details as may be required by the TANGEDCO from time to time.

Date :

Place :

Signature of the Authorized Signatory of  
the Applicant with designation

Seal of the Company



**List of documents to be furnished along with this format.**

Apart from the documents listed in the format, the following documents are to be enclosed.

1. Geographical location of the generating station.
2. Site plan in appropriate scale. The site plan should indicate following details
  - a. The proposed location of the connection point
  - b. Generators
  - c. Transformer
  - d. Site building
3. Memorandum & Articles of Association.
4. Authenticated descriptive write up about the plant process with process flow chart in case of industry co-existing with generator/captive generator/Co-generator.
5. Write up on generator protection scheme with protection diagrams in quadruplicate.
6. Documents in respect of the following
  - i) Site identification and land acquisition.
  - ii) Environmental Clearance
  - iii) Forest clearance
  - iv) Fuel arrangements
  - v) Water linkage
  - vi) CEIG safety certificate.
  - vii) TNPCB consent to establish/operate

7. Electrical single line diagram (SLD) of the plant. Location of Interface meter(s) and energy accounting meters (for auxiliary consumption, start up power consumption, generation of individual units and industrial loads etc.) shall also be included.
8. Copy of CEIG approved drawing with synchronizing arrangements
9. Copy of purchase order for the generator.
10. Generator Technical details & Generator Transformer details along with the signature of the authorized signatory, in the prescribed format below

### Generator Transformer Data

Sl. No	Description of details required	Data
1	MVA Rating	
2	Primary Voltage	
3	Secondary Voltage	
4	Type of cooling	
5	Winding configuration (Primary & Secondary )	
6	Breaker Rating in MVA	
7	Normal Tap setting	
8	Tap step ( off- Load and On-Load Tap)	
9	Tap ratio ( in %)	
10	Maximum and Minimum Tap number	
11	Maximum and Minimum Tap voltage	
12	Phase displacement	
13	% Impedance	
14	Leakage Reactance	
15	Resistance	
16	Reactance	

### Generator Details

Sl. No	Description of details required	Data
1	MW/MVA Rating	
2	KV Rating	
3	Armature Resistance (Ra)	
4	Direct Axis Reactance (Xd)	
5	Quadrature Axis Reactance (Xq)	
6	Negative Seq. Reactance (Xn)	
7	Zero Seq. Reactance (Xo)	
8	Direct Axis Transient Reactance (Xd)	
9	Quadrature Axis Transient Reactance (Xq)	
10	Direct Axis sub Transient Reactance (Xd)	
11	Quadrature Axis sub Transient Reactance (Xq)	
12	Inertia in MU/MVA	
13	Damping factor	
14	Winding connection	
	Mass details	
i)	Mass no	
ii)	Inertia	
iii)	Damping factor	
iv)	Stiffness Co-efficient	
v)	Capability Curve diagram to be enclosed	

11. In case of Lead Generators, the above details of each generator for lead group shall be enclosed separately.

### **Declaration for Lead Generator**

We the lead generator hereby declares that all the above details are true and correct. We the lead generator certifies that the formal agreement between the lead generator and the group of generator has been executed whereby the lead generator is authorized to submit the agreements on behalf of group generators as executed. We are also agreeable to furnish any other details as may be required by the TANGEDCO from time to time. We also agree for the following.

1. In case of captive generating plant in the group, the individual CGPs shall obtain the approval and consent as mentioned in the procedure. Similarly individual Co-generating plant in the group shall get the approval of the distribution licensee for Co-gen status separately.
2. Wherever consent from the distribution licensee is required such consent for the consumer shall be obtained as mentioned in the procedure before availing open access.
3. The qualifying requirement of captive power plant status has to be maintained by the individual generator and their captive users and proof furnished for the same by 30<sup>th</sup> April of the succeeding financial year.

Date :

Place :

Signature of the Authorized Signatory of the  
Applicant with designation

Seal of the Company of the  
lead generator

**FORMAT -2**

**Grid Connectivity Agreement For Fossil fuel based Generating Plant/ Captive Generating Plant / Co-Gen Plant / Renewable Energy generating plant with Distribution Licensee Network with interface voltage 33 KV and below**

This agreement made at \_\_\_\_\_ on this \_\_\_\_\_ day of \_\_\_\_\_ Two thousand \_\_\_\_\_ between M/s. \_\_\_\_\_ (Name Generating Plant and address) hereinafter called "the GP/CGP/Co-gen/RE holder " which expression shall wherever the context so permits means and includes the successors in interest, executors, administrators and assigns represented by Thiru. \_\_\_\_\_ Son of \_\_\_\_\_ officiating as ----- in the generating company and having authorization to execute this agreement on behalf of it as Party of the **First part**

AND

M/s Tamil Nadu Generation and Distribution corporation Ltd (Name of the Distribution Licensee) having its office at NPKRR Maaligai, 144, Anna salai, Chennai-60002 hereinafter called "Distribution Licensee" which expression shall wherever the context so permits means and includes the successors in interest, administrators and assigns represented by Thiru \_\_\_\_\_ S/o ----- (Superintending Engineer/-----EDC) as Party of the **Second part**

WHEREAS the parties herein have executed this agreement for Grid Connectivity of the GP/CGP/Co-gen/RE holder's Generator, with Distribution licensee's network.

This agreement is only for Grid Connectivity. The GP/CGP/Co-gen/RE plant holder has to execute separate agreement for Wheeling/ Open access after getting approval from the appropriate agency.

WHEREAS the GP/CGP/Co-gen/RE holder has sent to the Distribution Licensee, his proposal to synchronize Generating Plant having capacity of \_\_\_\_\_MW installed at \_\_\_\_\_village \_\_\_\_\_taluk in \_\_\_\_\_district / commissioned / to be commissioned on or about \_\_\_\_\_through the Distribution Licensee's Distribution network .

WHEREAS the GP/CGP/Co-gen/RE holder has paid the application fees wherever applicable as notified by the Tamil Nadu Electricity Regulatory Commission, hereinafter called "the Commission".

AND WHEREAS the Distribution Licensee has accepted the proposal of the GP/CGP/Co-gen/RE holder for Grid Connectivity of generator of the GP/CGP/Co-gen Holder to Distribution networks as per Lr. No. ----- F.----/ D.No.-----/ 20, Dt.-----on the terms and conditions hereinafter mentioned.

**NOW THESE PRESENTS WITNESSETH AND THE PARTIES HEREBY AGREE AS FOLLOWS:**

**TERMS AND CONDITIONS.-**

**1. Definitions.-**

In this agreement, -

1.1 **"Force Majeure"** means any event which is beyond the control of the parties to this agreement which they could not foresee or with a reasonable amount of diligence could not have foreseen or which could not be prevented

and which substantially affect the performance of either party such as but not limited to -

- (i) natural disasters (earthquakes, hurricane, floods);
- (ii) wars, riots or Civil Commotions and other upheavals;
- (iii) grid / distribution system's failure not attributable to parties hereto;

1.2 **"Inter connection point"** means

- (i) in relation to fossil fuel based generators, the Generating Plant's switchyard at which point the interconnection is established between the Generating Plant and the Transmission/Distribution system;
- (ii) in relation to wind energy projects and solar photovoltaic projects, inter connection point shall be line isolator on outgoing feeder on HV side of the pooling substation;
- (iii) in relation to small hydro power, biomass power and non fossil fuel based cogeneration power projects and Solar Thermal Power Projects, the inter connection point shall be line isolator on outgoing feeder on HV side of generator transformer;

1.3 **"Interface line"** means the electric line between the interconnection point and the nearest point at which the electric line could technically be connected to the existing distribution system; and

1.4 **'Meter'** means a 'Meter' as defined in the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006 as amended from time to time.

**2 Interfacing and evacuation facilities.-**

2.1 The GP/CGP/Co-gen/RE holder agrees to interface his Generating Plant with the Distribution Licensee's Transmission/Distribution network through 11/22/33KV lines and shall erect interfacing line from the point of generators



switchyard to Distribution/Transmission licensee's..... Substation and pay for the cost of bay at the Distribution/Transmission licensee's ----- substation/Switching Station erected as the case may be including cost of switchgear, metering, protection, data communication system which includes online data transfer to SCADA server and AMR data transfer, initial testing, commissioning and other arrangements etc. which will be executed by the Distribution Licensee towards augmentation. The generating company shall pay the cost within 30 days of receipt of cost of works.

- 2.2 The party to the first part will erect the interfacing line as per sec 9 and 10 (1) of E-Act 2003 as the case may be and complete the works within the time frame and the ownership of the line will rest with the company.
- 2.3 The party to the second part will complete the bay works and augmentation works, if any, in the substation co-terminus with the completion of works by party to the first part. In case where augmentation of the Transmission licensee's SS / TANGEDCO's SS is involved, the generator shall also bear the cost of bay extension, data communication system and initial testing and commissioning.
- 2.4 If the generating company or the TANGEDCO could not complete the works within the specified period, the parties to the agreement shall in mutual consultation agree for revised schedule for completion of works.
- 2.5 Where a dedicated distribution system used for open access has been constructed for exclusive use of an open access customer, the wheeling charges for such dedicated system shall be worked out by the licensee and got approved by the Commission and shall be borne entirely by such open

access customer till such time the surplus capacity is allotted and used by other persons or for other purposes.

2.6 In case intra state transmission system or distribution system is used by an open access customer in addition to inter-state transmission system, transmission charges and wheeling charges as fixed and approved by the Commission shall be payable for use of intra-state system in addition to payment of transmission charges for inter-state transmission.

2.7 The GP/CGP/Co-gen/RE holder and the Distribution Licensee shall comply with the provisions contained in Central Electricity Authority (Technical Standards for Interconnecting to the Grid) Regulations, 2007 which includes the following namely;

- (i)** Connection Agreement;
- (ii)** Site responsibility schedule;
- (iii)** Access at Connection site;
- (iv)** Site Common Drawings;
- (v)** Safety;
- (vi)** Protection System and Co-ordination; and
- (vii)** Inspection, Test, Calibration and Maintenance prior to Connection.

2.8 The GP/CGP/Co-gen/RE holder agrees to comply with the safety measures contained in section 53 of the Electricity Act, 2003 (Act 36 of 2003);

2.9 Both the parties shall comply with the provisions contained in the Indian Electricity Grid Code, Tamil Nadu Electricity Grid Code, the Electricity Act, 2003, other Codes and Regulations issued by the Commission / Central Electricity Authority and amendments issued thereon, from time to time; and

2.10 Both the parties shall comply with the guidelines issued by the Government of India / Government of Tamil Nadu, from time to time. Demonstrate

### **3 Conditions Precedent to the implementation of the Commissioning Instructions**

The applicant or intra -State Distribution Licensee shall have to get appropriate "Commissioning instruction" prior to actually first charging of the equipment through the grid. The charging instruction shall be issued only when the Distribution Licensee is satisfied (by acting reasonably) that:

- 3.1. the Connection Works have been completed;
- 3.2. the applicant has complied with its obligations as set out in the Offer Letter
- 3.3. the applicant/intra -State transmission licensee has demonstrated the voice & data communication facilities to SLDC with the payment of necessary charges towards terminal equipments at LD centre.
- 3.4. the applicant has completed the provision of ABT meter with DLMS facility and establishment of online data connectivity to the AMR server at SLDC with the payment of necessary charges.
- 3.5. the applicant/intra -State transmission licensee has obtained necessary approvals like PTCC, Electrical Inspectorate of CEA etc. from competent authority;
- 3.6. the applicant/intra - State transmission licensee has complied with its obligations under the Central Electricity Authority (Technical Standards for Connectivity to the Grid) Regulations, 2007 as amended from time to time.

### **4 Operation and Maintenance.-**

- 4.1 The GP/CGP/Co-gen/RE holder agrees that the starting current of the Generators shall not exceed the full load current of the machine and also

agrees to provide the necessary current limiting devices like thyristor during the starting.

- 4.2 The GP/CGP/Co-gen/RE holder agrees to minimize drawal of reactive power from the Distribution Licensee's Distribution network at an interconnection point as per the provisions of the Tamil Nadu Electricity Grid Code and the Indian Electricity Grid Code, as the case may be.
- 4.3 The GP/CGP/Co-gen/RE holder agrees to provide suitable automatic safety devices so that the Generator shall isolate automatically when the grid supply fails.
- 4.4 The GP/CGP/Co-gen/RE holder agrees to maintain the Generator and the equipments including the transformer, switch gear protection equipments and other allied equipments at his cost to the satisfaction of the authorized officer of the Distribution Licensee.
- 4.5 The changing of the rupturing capacity of the switch gear and settings of the relays, if any, shall be subject to the approval of the authorized officer of the Distribution Licensee.
- 4.6 The GP/CGP/Co-gen/RE holder agrees that the Distribution Licensee shall not be responsible for any damage to his Generating Plant resulting from parallel operation with the Transmission/Distribution network and that the Distribution Licensee shall not be liable to pay any compensation for any such damage.
- 4.7 The Generating Plant shall be maintained effectively and operated by competent and qualified personnel.
- 4.8 In case of unsymmetrical fault on HV bus, the GP holder shall share the fault current according to impedance of the circuit. To meet such contingency and

for safe operation of the Generating Plant, the GP holder shall provide the following scheme of protection, namely, -

- (i) Separate overload relays on each phase and earth fault relays shall be installed by the GP holder. Under no circumstances, these relays shall be by-passed;
- (ii) With suitable Current Transformer and relay connections, the load sharing by the GP holder and Distribution Licensee shall be limited to their rated capacity;
- (iii) Adequate indication and control metering for proper paralleling of the Generating Plant on the HV bus shall be made available; and
- (iv) Protection co-ordination shall be done by the Distribution Licensee in consultation with the Regional Power Committee / State Transmission Utility and relays and the protection system shall be maintained as per site responsibility schedule;

4.9 Grid availability shall be subject to the restriction and control as per the orders of the State Load Dispatch Centre and as per Tamil Nadu Electricity Grid Code;

4.10 The GP/CGP/Co-gen/RE users can avail power from the generating plant subject to the Restriction and Control measures imposed/approved by the Commission from time to time.

4.11 If the interfacing line is established by the generator, the interfacing line(s) shall be maintained by themselves after availing proper line clear from the concerned SE/EDC. Further the generator agrees to pay to the distribution licensee for the cost of maintenance of bay at the licensee's substation or cost

of Operation and maintenance of Switching station as the case may be where the interfacing line is terminated on annual basis. Bills for the same will be sent by SE/EDC concerned, within three days of succeeding year and the generator will pay the bill within five days of receipt of bill.

- 4.12 The Generator may also request the licensee to maintain the interfacing line and if the interfacing line is maintained by the Distribution licensee, the cost of maintenance of line including cost of bay maintenance / switching station maintenance as the case shall be paid by the generator.

## **5 Metering Arrangements. -**

- 5.1 ABT Meters with DLMS facility: - ABT compliant interface meters with DLMS facility shall be installed as specified in the Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006 as amended from time to time. The meters shall be provided by the STU or the Transmission Licensee as the case may be, at the cost of applicant both at the injection and drawal points. The applicant can opt for supply and installation of meters as per the standards recommended by the STU or the Transmission Licensee, as the case may be and approved by the Commission. The cost of meters and installation, have to be borne by the applicant and the readings shall be taken by the Licensee as per the CEA regulations.
- 5.2 The meters shall have facility for communication of data on real time basis to SCADA server and AMR data transfer suitable to the protocol specified by STU / licensee.

- 5.3 The ABT meters with DLMS facility shall be open for inspection by any person authorized by the State Transmission Utility or the State Load Despatch Centre or the Distribution Licensee.
- 5.4 The Distribution Licensee may provide Check Meters of the same specifications as that of the main meters.
- 5.5 The applicant can have a standby meter of the same specification tested and sealed by the Distribution Licensee.
- 5.6 Main and Check Meters shall have facility to communicate its readings ( day survey, load survey and instantaneous data) to State Load Despatch Centre / Transmission Control Centre on real time basis or otherwise.
- 5.7 The Main and Check Meters shall be periodically tested and calibrated by the generators/ Licensee as the case may be in the presence of other party involved. Both parties shall seal Main and Check meters. Defective meter shall be replaced immediately. The periodicity of testing, checking, calibration etc. will be governed by the regulations issued by the Central Electricity Authority in this regard.
- 5.8 Reading of Main and Check meters shall be taken periodically at appointed day and hour by authorized officer of the Distribution Licensee in the presence of the applicant or his representative.
- 5.9 Check meter readings shall be considered when Main Meters are found to be defective or stopped functioning. Provided that, if difference exists between the readings of main and check meters, viz. main meter reading exceeds twice the percentage error applicable to relevant class, both meters shall be tested and the defective meter shall be immediately replaced and reading of other will be considered.

- 5.10 If during test or calibration, both the main meter and the check meter are found to have errors beyond permissible limits, the bill shall be revised for the previous 3 (Three) months or for the exact period if known and agreed upon by both the parties, by applying correction as determined by the Distribution Licensee to the consumption registered by the meter with lesser error.
- 5.11 The applicant shall check the healthiness of metering arrangement by superficially checking indicator lamps or by taking readings as frequently as possible. If both the main meter and the check meter fail to record energy either due to the blowing of the P.T. fuses or due to any other causes, the energy imported or exported may be arrived at based on the standby meter, if available, or by mutual agreement of the parties involved.
- 5.12 The main and check meters shall be tested for accuracy as per the CEA (Installation and Operation of meters) Regulations 2006 and amendments thereon. The meters may be tested using NABL accredited mobile laboratory or at any accredited laboratory in the presence of parties involved. Both parties shall seal main and check meters. Defective meters shall be replaced immediately.
- 5.13 Energy Accounting Meters: The generator shall provide energy accounting meter as per the provisions of CEA Regulations 2006 and its subsequent amendments in order to ascertain the quantum of energy generated unit wise, Auxiliary consumption and consumption of energy for startup power. The energy meters shall be provided at various locations as agreed between parties to the agreement and approved by the licensee in the drawing.

## **6 Charges. -**

The following are the charges that an applicant has to pay



6.1 **Startup power Charges: –**

In case of outage of generator, the power drawn by the Generating Plant for startup and other purpose shall be charged at the rate fixed in the Commission's Tariff order/other relevant orders issued from time to time.

6.2 **Transmission and Wheeling charges: -** Transmission and Wheeling charges

shall be payable by the CGP holder as per the order of the Commission for the time being in force.

6.3 **Reactive energy charges: -** Reactive Power Charges is recoverable as per the regulation / Code /order in force.

6.4 **Parallel Operation charges :** Captive Generating Plant who opt for parallel

operation of the generator with licensee (without availing open access) for safe and secure operation of the generator has to pay Parallel Operation charges every month as notified by TNERC. As per these Regulations, parallel operation charges are to be paid for net capacity (ie installed capacity less than open access capacity) at the rate up to Rs.30,000/- per MW/month and amended by TNERC from time to time. The bills for the same will be sent by the SE/EDC concerned within three days of succeeding calendar month and the generator shall pay the bill within five days of receipt of the bill.

6.5 **O&M Charges: -** Operation and Maintenance (O&M) Charges towards bay(s)

provided at **STU's/Distribution** substation/Switching Station erected as the case maybe shall be borne by the applicant as per prevailing orders of the commission.

6.6 Any additional charges that may be notified by the Commission at a later date shall also be levied, from the date as approved by the Commission.

- 6.7 In case of deviation between the schedule and the actual injection or drawal in respect of an applicant, settlement will be made as per the provisions of Commission's prevailing Deviation Settlement Mechanism Regulations.
- 6.8 The existing procedure will be followed for collection of application fee and all other charges until procurement of necessary software to implement the accounting procedure as per the Regulations.
- 6.9 In case the applicant fails to make any payment due to STU/Distribution licensee within the specified due dates, open access/ connectivity shall be discontinued after issue of 15 days notice without prejudice to its rights to recover the charges by suit.

## **7 Standard terms and conditions**

- 7.1. Any power injected in to the grid without valid contractual agreement and open access approval will not be accounted for payment except in the case specified in the regulations (Regulation 8(6)). The same will not be treated as sale of power to the distribution licensee and there will be no liability for making payments under any circumstances, by the licensee.
- 7.2. The applicant should adhere to the directions received from the State Load Despatch Centre which are covered under Sec 32,33 & 37 of Electricity Act,2003 and directions if any, issued under Sec.11 of Electricity Act,2003.
- 7.3. The State Transmission Utility /TANGEDCO will not be responsible for any damage to the Company's generator sets or other equipment as a result of such grid connectivity.
- 7.4. There should not be any fluctuation or disturbance to the grid due to paralleling of the Company's generator sets. The company shall provide

adequate protection as required by TANTRANSCO/TANGEDCO to facilitate parallel operation of the generator sets with the grid and to prevent any disturbance in the grid. The company shall undertake to install such equipments at their own cost to ensure that they will safeguard the TANTRANSCO/TANGEDCO's property in accordance with this condition.

- 7.5. The generator of the company shall be maintained effectively and operated by competent and qualified persons.
- 7.6. The applicant shall adhere to the various provisions of Electricity Act 2003, Commission's various orders, Intra state open access Regulations 2014, Tamil Nadu Electricity Grid Code etc., and their amendments issued from time to time.
- 7.7. The applicant shall adhere to the instructions of SLDC for grid availability and safe operation of the grid.
- 7.8. The Company shall make good the loss, if any, due to any damage that may occur to the equipments or personnel of the distribution licensee installed in connection with power supply to the company on account of parallel operation.
- 7.9. In case of mere parallel operation of generator(s) with the licensee's network without evacuation /open access there shall not be any power export into the licensee network under any circumstances and the generator shall install appropriate protection arrangements for preventing such exports. In case of power export or load over throw is noticed action deemed fit as per the provisions of E-Act 2003 will be taken, and further the generator shall pay for the damages/loss incurred by the distribution licensee.

- 7.10. The permission accorded for parallel operation shall not absolve the GP/CGP/Co-gen/RE holder from getting other statutory approvals required from various state and central government agencies, such as the approval of the Chief Electrical Inspector to Government for installation, operation and maintenance etc.,
- 7.11. The GP/CGP/Co-gen/RE holder shall bear the entire cost of all equipments required for paralleling with the grid.
- 7.12. Periodical inspection of the Generating station, Switch yard, Substation, tie lines and other electrical installation of the generating station shall be got carried out by the Chief Electrical Inspector to Govt. of Tamil Nadu
- 7.13. Notice of accidents in such form and within such time as may be prescribed by the State Government should be sent to Electrical Inspector and to such other authorities as State Government may or by special order directs, under Electricity Act, 2003.
- 7.14. If any Tax under Tamil Nadu Tax on consumption or sale of Electricity for either sale of energy to persons other than TANGEDCO or captive consumption, such tax shall be paid along with the returns as prescribed in the Tamil Nadu Tax on consumption or sale of Electricity Act 2003.
- 7.15. In case of necessity to work on the secondary side of the CTs and PTs it should be done only in the presence of authorized TANGEDCO representatives.
- 7.16. The applicant shall undertake to install such equipments at their own cost to ensure that harmonics are maintained within the prescribed limit as per the CEA norms.

- 7.17. TANGEDCO will not be responsible for loss of generation if any, due to breakdown of lines or any evacuation constraint and no compensation is payable by TANGEDCO to the GP/CGP/Co-gen if the cause is attributable to the generator.
- 7.18. In case the generator fails to make any payment due to TANGEDCO within the specified due dates, wheeling/energy adjustment will not be made and action will be taken to withdraw the Open Access/ Connectivity granted.
- 7.19. The company should back down / shutdown the generation / generator as per the instruction of LD centre as and when required according to the grid conditions and no compensation shall be claimed from TANTRASCO/TANGEDCO.
- 7.20. The company shall arrange to provide necessary communication facilities (Telemetry arrangements) as per the requirements of STU/SLDC to communicate the data required on real time basis to the SLDC, Chennai
- i) The Speech communication to adjacent stations shall be provided either by land line or PLCC depending on the infrastructure available at the premises of the generating company.
  - ii) The company shall provide their data through 64/256/512 Kbps MPLS network through any of the service providers via IEC-104 protocol at their own cost. The list of the RTUs and the service provider may be intimated to the P&C wing of TANTRANSCO. The service provider shall be suitably intimated that only one Ethernet port will be given to them at control centre end irrespective of the number of RTUs connected to their network.

iii) Towards terminal equipments at LD centre the company has to pay Rs. 2,00,000/- for below 10 MW generator and Rs.3,00,000/- for above 10 MW generator to TANGEDCO.

iv) Towards deposit amount for leased line charges, the company has to pay the amount to TANGEDCO which will be informed in due course. Subsequently the company has to pay the leased line charges annually to TANGEDCO as per the bill received from BSNL.

7.21 The company has to comply with TANGEDCO's orders on R&C measures.

7.22 On expiry of agreement, the company has to de-synchronize the generators from the grid and the company has to synchronize the generators only after issue of fresh approval for grid connectivity, from the Nodal agency. The company has to apply at least 30 days in advance before expiry of the existing agreement(s) for grid connectivity. It is the responsibility of the company to apply for fresh approvals within specified time.

7.23 The TANGEDCO reserves the right to withdraw the concurrence for grid connectivity to operate the company's generator set in parallel with grid if any of the condition is violated.

7.24 Any alteration or deletion in the terms and conditions of this agreement is to be carried out based on mutual agreement between the distribution licensee and the company.

7.25 TANGEDCO will not compensate the generator under any circumstances in case power could not be evacuated due to various reasons not limited to such as

breakdown of line/equipment of TANGEDCO/TANTRANSCO, grid disturbance etc. However all effects will be taken to maintaining the TANGEDCO/TANTRANSCO's equipment to the appropriate standard.

## **8. Specific Conditions**

8.1 On completion of all erection works (generator/lines, etc) by the generating company as well as by the Distribution licensee, provision of ABT meter with DLMS facility and establishment of online data connectivity with AMR server at SLDC, the company shall inform Distribution licensee/Nodal agency for concurrence of synchronization of generator with the distribution system and Distribution licensee shall issue concurrence for the same, taking into account the field condition.

8.2 Synchronizations of the generating unit with the distribution system shall be permitted only after ensuring proper protection arrangement by officials of Distribution licensee/SLDC and after obtaining statutory clearances like consent to operate from MOEF, TNPCB, and clearance from various authorities such as CEIG etc. The synchronization (for the first time) shall be in presence of the officials of Distribution licensee and shall be with consent of SLDC.

8.3 It is the sole responsibility of the generator to declare COD of the generator. The date of declaration of COD and the capacity of the individual unit shall be final.

8.4 At the time of synchronization as well as at the time of COD, meter readings at Interface point shall be taken.

8.5 The generator shall be synchronized in presence of TANGEDCO's officials. Payment for the energy pumped if any for testing and commissioning purpose from the date of synchronization till declaration of COD will be paid as per the formula

notified in TNERC's Amendment to the terms and condition for determination of Tariff Regulations 2005, dt.09.04.2014. On attaining COD the company shall furnish the details of energy pumped till COD to this office for fixing of tariff as per the formula notified by TNERC. Necessary clearance shall be obtained from JLDC/SLDC before pumping energy for testing and commissioning

8.6 The company shall inform the date of synchronization and COD to this office and the SE/EDC concerned and the bills for such supplies shall be submitted to the SE/EDC concerned for payment.

## **9. Captive Generating Plants / Co- generating Plants**

### **9.1 Captive Generating Plant Status verification**

In case of captive generating plants, they shall maintain CGP status as per Rule 3 of Electricity Rules and shall furnish the prescribed documents and formats as per TNERC's order in R.A.No.7 of 2019, dt.28.01.2020 for verification of CGP status as and when required by the distribution licensee.

## **10. CO-Generating Plant Status verification**

10.1 The Co-gen holder shall furnish necessary documents and maintain Co-gen status as per MOP resolution A-40/95- IPC-1, dt.06.11.1996 and TNERC's order No.4, dt.15.05.2006.before 31<sup>st</sup> January of succeeding Calendar year to the SE/EDC concerned.

## **11. Applicability of the Acts, Regulations and Guidelines. -**

11.1 The parties shall be bound by the provisions contained in the Electricity Act, 2003, Regulations, notifications, orders and subsequent amendments, if any, made there under from time to time by the Commission and the guidelines issued by the Government of India / Government of Tamil Nadu, as the case may be.



**12. Agreement Period. -**

12.1 This agreement is valid till the generator is connected with the grid.

12.2 In case of any breach or violation of any of the clauses in this agreement or any other valid reasons, by any party, the other party shall be at liberty to cancel this agreement by giving thirty days notice.

12.3 The parties to the agreement may at any time renegotiate the existing agreement mutually within the framework of the then existing relevant regulations, codes and orders of the Commission in force for reasons other than clause 10.2 of this agreement.

**13. Settlement of Disputes. -**

13.1 A clause on reconciliation of energy /payment could be introduced if any dispute or difference of any kind whatsoever arises between the parties to this agreement, it shall, in the first instance, be settled amicably, by the parties, failing which either party may approach the Commission for the adjudication of such disputes under section 86 (1) (f) of the Electricity Act, 2003.

**14. Force Majeure. -**

14.1 Both the parties shall ensure compliance of the terms and conditions of this agreement. However, no party shall be liable for payment of any claim on any loss or damage whatsoever arising out of failure to carry out the terms of this agreement to the extent that such failure is due to force majeure. But any party claiming the benefit of this clause shall satisfy the other party of the existence of such an event(s), within 30 days of occurrence of the event(s)

In witness whereof Thiru. \_\_\_\_\_ acting for and on behalf of \_\_\_\_\_ (GP holder) and \_\_\_\_\_ Authorized Officer of the Distribution Licensee acting for and on behalf of the Distribution Licensee have hereunto set their hands on the day, month and year hereinabove first mentioned.

In the presence of witnesses:

- 1)
- 2)

Signature

GP holder  
Common seal

In the presence of witnesses:

- 1)
- 2)

Signature

Authorized Officer of the STU/  
Distribution Licensee